

District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
Ph (O) : 0134-226360, E-mail: eeujshrd@yahoo.com



TC-12836

TEST REPORT

Name and Address of Organization/ Customer?	Kaushik, Public School, Haridwar Bhagwanpur Road Implikera, Haridwar,		
Test Report ID	278 UJS DE WQ TMS/2025-26	Reporting Date	27/06/2025
UJR No.	TC-12836/2400000119f	Sample Location	Kaushik Public School
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DE WQ TMS UJS/2025-278		
Date of Start of Analysis:	26/06/2025		
Date of End of Analysis:	27/06/2025		
Date and Time of Sample Received:	26/06/2025 & 4:45 pm		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11), 2022,	6.70	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	274	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.45	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	168	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	202	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	67.2	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	8	250	1000
8.	Magnesium as Mg, mg/l	APIA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	8.26	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less than 1	5	15
10.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable

Note:

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
- The results apply to the sample as received
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

M. Singh
District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar

Anil
Authorized Signatory
(Er. Anjali Palariya)
Review and Authorized By
District Level Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar



TEST REPORT

Name and Address of Organization/ Customer	Kaushik Public School, Haridwar Bhagwanpur Road Imlikera, Haridwar,		
Test Report ID	278/UJS/DLWQIML/2025-26	Reporting Date	27/06/2025
Product Description	Drinking Water	Sample Location	Kaushik Public School
Reference Sample Identification:	DLWQIML/UJS/2025-278	Sample Collected by	Customer
Date of Start of Analysis:	26/06/2025		
Date of End of Analysis:	27/06/2025		
Date and Time of Sample Received:	26/06/2025 & 4:45 pm		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	Nitrate, mg/L, max	APHA 23 RD Ed. 4500- NO3-B	2.58	45	No Relaxation
2.	Sulfate, mg/L, max	APHA 23 RD Ed; 4500-SO4 2-E	5.1	200	400
3.	Iron (as Fe), mg/L, max	APHA 23 RD Ed; 3500- Fe - B	Less than 0.5	1.0	No Relaxation
4.	Flouride, mg/L, max	APHA 23 RD Ed; 4500- F - D	Less than 0.2	1.0	1.5
5.	Residual Free Chlorine, mg/L, Min	APHA 23rd Ed.-4500- Cl-G	NA	0.2	1.0
Bacteriological Parameters					
6.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
7.	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

note:

The results listed refer only to tested sample and applicable parameters.
 This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
 The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
 The results apply to the sample as received
 The laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

(Signature)
 District Water Quality Testing Monitoring
 Laboratory,
 Uttarakhand Jal Sansthan, Haridwar

(Signature)
 (Er. Anjali Palariya)
 Authorized signatory,
 Review and Authorized By
 District Level Water Quality Testing Monitoring
 Laboratory,
 Uttarakhand Jal Sansthan, Haridwar

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **55**

Dated: 27/09/2025

It is certified that an inspection team headed by RAKESH CHANDRA BAMPARA (ASSISTANT ENGINEER)

(Name of Officers with designation) from UTTARAKHAND JAL SANSTHAN, HARIDWAR PHED

inspected the KAUSHIK PUBLIC SCHOOL, BALIKHERA, HARIDWAR

(Name & Address of the school) on 25/09/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 278/UJS/DLWQTM/2025-2026 dated 27/09/2025

of HARIDWAR (PHED Lab) certified that

the KAUSHIK PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal: **Assistant Engineer**

Name: **Uttarkhand Jal Sansthan**

Designation: **Haridwar**

Name & Address of the Office / Department: **MAYAPUR, HARIDWAR**

To KAUSHIK PUBLIC SCHOOL, BHAGWANPUR ROAD,
IMLIKHERA, HARIDWAR- 247667
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



उत्तराखण्ड जल संस्थान

27/06/2025

Mayapur

दिनांक
O-MB/2373

MP 17467099

भाग पत्रिका सं०
श्री / श्रीमती
पता
कोशक पीब्लेक स्कूल हरिद्वार
भादवपुर रोड इमारेखेड़ा हरिद्वार

तक
माह

जल मूल्य	जल कर	सीवर कर	सीवर-सीट	अन्य प्राप्ति	जमा राशि (रु०)
0.00		0.00		1650.00	1,650.00
<p>विल सं० O-MB/2373/62B25/OEthe जमा राशि 1,650.00 शब्दों में ONE THOUSAND SIX HUNDRED FIFTY द्वकाया राशि 0.00 अतिरिक्त जमा राशि 0.00</p> <p>27 06 2025 को रिसेट राशि Cash द्वारा प्राप्त हुई</p> <p>अधिकृत स्वाक्षरकर्ता</p>					